

**PIMPRI CHINCHWAD NEW TOWN DEVELOPMENT AUTHORITY,**  
NEAR AKURDI RAILWAY STATION, PUNE-44

**COMMON SET OF DEVIATION**

**Name of work :-Construction of Play grounds in various sectors**

**E -TENDER NOTICE NO 16 FOR 2013-14 ( Common for E Tender No. 39, 40, 41, 42, 43, 44,45 )**

Common set of deviation/ clarification based on pre-bid conference held in the office. The Chief Executive Officer , PCNTDA on 06/02/2014 @ 11:00 hrs to be read with the tender and to be treated as part of the tender. This will be part and partial of tender document.

**(Part I :- Clarification)**

<b>Sr. No.</b>	<b>Queries Raised by</b>	<b>Reference</b>	<b>Queries/request raised by Bidders</b>	<b>Clarifications</b>
(1) i	M/s BVG India Ltd,	Chapter-I ClauseNo 5.8	<b>Eligibility Criteria for Technical Experience for Bidder :-</b> Requested to consider up to 50% estimated cost put to tender	NIT prevails
ii		<b>Chapter-I Clause No 5.9 (i)</b>	Requested to consider the construction of play ground, club house, Tennis court, Scatting ring etc. other sports activity under the work name Garden Development in Govt./Semi Govt/Local Bodies	NIT prevails
iii		<b>Drawing</b>	There are no any Drawing details shown in tender, requested to provide us	Drawings are available in Tender Document.
iv			<b>Addl. DD as per requirement of Addl, Condition for mobilization of plant</b> Requested , ple clarify about Mobilazation of plant, become this type condition are made for road construction work for erection of asphaltting plant	Mobilisation plant not required so DD not required for the same
v		<b>Schedule B Item No. 4.13</b>	S & E Strip, Rate/Kg for Tender No, 5 is Rs, 7055/- And Tender No, 4 is Rs. 100/- Request to clarify the actual rate for same item	S & E GI strip, rate/ kg for tender no. 5 is written as Rs. 7055/-, Which should be read as Rs. 100/-
vi		<b>Schedule B ItemNo4.12</b>	There are not metioned items rate, but total amount of items is mentioned, so request it that pl clarify	Tender No. 5, Schedule B electrical works, rate for Item No. 4.12 was not written, It shall be read as Rs. 1786/-
Vii (a)		<b>Form No. 1</b>	Age of Machinery is not more than 5 years as on 31/03/2012 Generally good working condition machinery life was 10 years, so we request is that pl consider the life of machinery up to 10 years old as on 31/03/2012	Age of Machinery is not more than 5 years as on 31/03/2014

(b)		<b>Form No, 1</b>	Sr. No. 2 Motor grader should own Machinery Request to accept the Machinery "Motor Grader" was appoint to this work on lease/rent basis instead of Own Machinery.	Sr. No. 2 rented or leased Motor Grader will be allowed.
(c)		<b>Form No. 1</b>	Sr. No. 3 Pneumatic Tyred roller should own Machinery Requested to accept Vibratory roller or Pnematic Tyred roller on Lease basis/own for this work	Sr. No. 3 rented or leased Motor Grader will be allowed.
viii			<b>Site Availability</b> It is also requested to confirm the 100% availability of site to immediate start the work.	NIT prevails
(2)	<b>M/s B.K . KHOSE</b>	Chapter - Condition no.13(14)	As per Detailed tender notice condition no.13 (or 14 ) states, the controversy, i.e.each contractor can bid only one work and similarly any contractor can bid to only two projects. Please clarify , what to say ? In this matter, we request you to allow all the contractors to bid any or all the bids, please and to avoid the over loading of work to some one contractor, it can be restricted by allotting only one work or two work to each contractor, by opening tenders serially. If the contractor success in the bid( or lowest ) of work No. 1, 2 or 3 etc., serially, their next tender will not be opened, So , that everybody will get the chance to participate, all the tenders and opportunity to getting the work. As this is in practice in other government & semi government department like PCMC,PWD,UOP etc.	1)All the works pertaining to construction of compound wall as notified in Tender notice No. 18 & 21 for 2013-14 shall be opened in a sequence. Such sequence of work shall be arranged in descending order as per the cost put to tender.  2)Contractor can submit tenders for more than one work but PCNTDA, will allot maximum two works considering contractors balance available bid capacity and lowest offer

Contractor

EE – (Electrical)

EE (A),

Superintending Engineer

CAFO

CEO

**ADDENDUM AND CORRECTIONS**

**E -TENDER NOTICE NO. 16 FOR 2013-14 ( E Tender No. 39, 40, 41, 42, 43, 44, 45 )**

**Name of work :-Construction Playground and Hawkers Zone In Various Sectors**

Common set of deviation/ clarification based on pre-bid conference held in the office. The Chief Executive Officer , PCNTDA on **06/02/2014 @ 11:00** hrs to be read with the tender and to be treated as part of the tender. This will be part and partial of tender document.

<b>Sr. No.</b>	<b>Clause As per NIT</b>	<b>Read As</b>
<b>1</b>	Sector No 19, Playground Schedule B, Item - Supplying Erecting Metal Halyde lamp double ended, 230V, 70 Watt Rate Rs. 263.00 Amount Rs 3681.3	Sector No 19, Playground Schedule bB, Item - Supplying Erecting Metal Halyde lamp double ended, 230V, 70 Watt Rate Rs. 677.00 Amount Rs 9478/-
<b>2</b>	Liaisoning Work for gettign approval to the electrical installations done as per above and permission to charge the installation for commercial use from MSEDCL and PWD electrical inspector, Amount Rs 75000/-	Liaisoning Work for gettign approval to the electrical installations done as per above and permission to charge the installation for commercial use from MSEDCL and PWD electrical inspector, Amount 69204/-
<b>3</b>	For sctor no 4 / 9/10/19/28 Schedule B Electrical Work Lionsioning work and MSEDCL supervision charges	For sctor no 4 / 9/10/19/28 Schedule B Electrical Work Lionsioning work and MSEDCL supervision charges will be reimbursed against actual payment receipts .

Contractor

EE – (Electrical)

EE (A),

Superiteding Engineer

CAFO

CEO

